



APPLICATION FIELD: FOOD PROCESSING, BREWERY, MILK, BOTTLED WATER, SOFT-DRINK MANUFACTURING

Many gases are used for different reasons in the food and beverage producing industries. Water is the major raw material at the beginning and the end of the process, which has to be treated regarding odour and sterility. The vessels and pipes need to be cleaned regularly with sterilising fluids which can generate toxic gases that become a threat to workers. For carbonation and during fermentation, CO₂ is used in high concentrations. The refrigerating and cooling system can contain pressurised ammonia which needs to be monitored to protect people and property.

Under certain circumstances the gases from the chemicals in use can become a threat to human health, because they are either toxic or flammable. This is why workplace monitoring is necessary. Containers in contact with food and processed raw materials, like water, need to be sterilised or

disinfected. The sterilisation of water required for the production of beverages is a significant subject due to the increased demand for water of good quality (taste, odour) by production plants. This can be done by applying gases like Ozone, Chlorine, Chlorine Dioxide or Hydrogen Peroxide. Generators produce the Ozone from air or oxygen with the aid of electrical discharges. It is then brought into contact with the medium being treated in reaction chambers. Chlorine is stored in cylinders and Chlorine Dioxide can be chemically generated on-site. Workers must have protection against leaks from the processes where these gases are used and stored.


The production process and the storage of goods require controlled temperature and environmental conditions, therefore refrigerating and cooling systems are widely used. Cooling fluids like Ammonia, Hydrocarbons or Halogenated Hydrocarbons are circulating in the cooling systems under pressure and can leak to pose a danger to workers. Monitored areas which should be considered are heat exchangers, joints, compressors and valves.

Carbon Dioxide will be naturally generated by the fermentation of wine and beer or added later to carbonise the beverages. This gas can accumulate on low levels from leaks and lead to asphyxia if undetected. To prevent leaks and system breakdowns, gas detection systems may be required to monitor the workplace insuring concentrations are below the Threshold Limit Value (TLV).

Chlorine Cl₂ is a very toxic, corrosive gas used for disinfecting. It is stored in cylinders at high concentrations and blended down to the concentration used in the process or dissolved in water.

TLV/TWA	TLV/STEL	TLV/IDLH	NIOSH/ceiling
1 ppm	3 ppm	25 ppm	0,5 ppm 15 min

In more and more applications, Chlorine Dioxide ClO₂ is used instead of Cl₂. Traditional oxidising agents (Chlorine and Bromine) suffer from pH constraints and corrosion problems. ClO₂ in water is more stable than other oxidising biocides and compatible with most water treatment chemistry. Chlorine Dioxide gas is a highly unstable substance. Long stagnation of the vapours will result in an explosive decomposition:



ClO₂ vapours are reactive with most organic compounds.

GAS DETECTION IN FOOD & BEVERAGE INDUSTRY



TWA
0.1 ppm

STEL
0.3 ppm

Ozone (O₃) is one of the strongest oxidising agents available. It is used to eliminate organic waste, reduce colour, odour and total organic carbon in water. Ozone is created in a number of different ways, including ultra violet (UV) light, corona discharge of electricity through an oxygen stream (including air), and several others. In treating small quantities of waste, UV ozonators are the most common, while large-scale systems use either corona discharge or other bulk ozone-producing methods. Ozone is formed as oxygen (O₂) is struck by a source of energy. The bonds that hold the O₂ together are broken and three O₂ molecules combine to form two O₃ molecules. The ozone begins to break down fairly quickly and doing so reverts back into O₂. The bonds holding the oxygen atoms together are very weak, which explains why ozone acts as a strong oxidant. In environmental air, the O₃ concentration can stay in the ppm ranges for a long time, making workplace monitoring essential.

TWA
0.1 ppm

STEL
0.3 ppm

Environmental background concentrations of O₃ may also need to be taken into account during Summer time. Sterilising gases have strong affinity to humidity and surfaces, so if a sampling system is used all tubing should be TEFLON.

If pressurised cooling fluids are being used in refrigerating and air conditioning systems, leak monitoring is essential. A small leak at a pipe joint can have a great impact and cause a lot of damage if not detected early. Cases are known where personnel have been intoxicated and stored goods have been destroyed by exposure to leaking Ammonia. Please refer to RC Systems APN-1042 for more information.

In breweries and wineries odourless carbon dioxide CO₂ is naturally generated in the malting, fermentation and storage process. Because it is heavier than air, CO₂ may collect in poorly ventilated areas or confined spaces in low level clouds replacing the oxygen. The same can happen in the beverage industry where CO₂ is used for carbonation of soft drinks and mineral water. CO₂ detectors are always used to monitor the concentrations and alert personnel and control fans. Selected thresholds for pre-alarms are 1000 ppm to 3000 ppm and main alarm is 5000 ppm for CO₂. Transmitters should be mounted at low levels since CO₂ is much heavier than air. They should be protected from mechanical damage and against water ingress if washed down occasionally.

TLV
5000 ppm

STEL
15000 ppm

MAK
5000 ppm

RC SYSTEMS' RECOMMENDATION:

Wired Gas Detection System		
Gases	Detectors	Controllers
Cl ₂ , NH ₃ , O ₃ , ClO ₂	SenSmart 5100/6100 EC	ViewSmart 400 (Up to 4 points) ViewSmart 1600 (Up to 16 Points) ViewSmart 6400 (Up to 64 Points)
CO ₂	SenSmart 5400/6400 IR	
Wireless Gas Detection System		
Gases	Detectors	Controllers
Cl ₂ , NH ₃ , O ₃ , ClO ₂	SenSmart 7100 EC	WNR WaveNet Receiver
CO ₂	SenSmart 7400 IR	(Up to 32 Points)

45+ YEARS IN GAS DETECTION

ISO 9001:2015 CERTIFIED CSA CERTIFIED CLASS 1, DIV 1 & 2
LOCAL HMA STOCK, SERVICE & CALIBRATION
IECEX COMING SOON